

TEST REPORT

Order no: 21.04.2021

Signature: SL/Z-244/DIN4102-B1/315a/2021

Police, 11.05.2021

Test methods:

1. DIN 4102-1:1998-05 Fire behaviour of building materials and building components - Part 1: Building materials; concepts, requirements and tests.
2. DIN 4102-16:2015-09 Fire behaviour of building materials and building components - Part 16: "Brandschacht" tests
3. DIN 53438-2:1984-06 Testing of combustible materials; response to ignition by a small flame; edge ignition
4. DIN 53438-3:1984-06 Testing of combustible materials; response to ignition by a small flame; surface ignition

Content of request: Testing according to DIN 4102-1:1998-05 (building class B1)

Sponsor: MIRANDA Spółka z o.o.
Jedwabnicza 1
62-700 Turek
Poland

Material: 100% PES knitted fabrics finished with WPL/OG, WPL D/OG in the weight range: 94 - 197 g/m² intended for advertising purposes

Composition: -

Manufacturer/supplier: MIRANDA Spółka z o.o.
Jedwabnicza 1
62-700 Turek

Assessment: The material fulfils the requirements of the building class B1 according to DIN 4102-1:1998-05

Validity of test report: 11.05.2026

The reprint and the copying: only with the agreement of MIRANDA Spółka z o.o.

Without the written consent of the Sychta Laboratory the report can be copied only in one piece.

Report applies only to the sample tested and is not necessarily indicative of the qualities of apparently identical or similar products.

Content of test report: seven pages with signature and numbers.